TOSHIBA
Leading Innovation

TCTC-E18-RES003

Engineering Data Book

Inverter Multi System R32

Outdoor Unit (2 Rooms)

RAS-2M14U2AVG-E

Contents

1. Line up

RAS-2M14U2AVG-E

Type	Appearance	Model name	Capacity rank
High wall DSK9		RAS-M10PKVPG-E	10k
		RAS-M13PKVPG-E	13k
High wall SHORAI		RAS-M05PKVSG-E	05k
		RAS-M07PKVSG-E	07k
		RAS-B10PKVSG-E	10k
		RAS-B13PKVSG-E	13k
High wall MIRAI		RAS-B05BKVG-E	05k
		RAS-B07BKVG-E	07k
		RAS-B10BKVG-E	10k
		RAS-B13BKVG-E	13k
Ducted		RAS-M07U2DVG-E	07k
		RAS-M10U2DVG-E	10k
		RAS-M13U2DVG-E	13k
Compact 4-way		RAS-M10U2MUVG-E	10k
		RAS-M13U2MUVG-E	13k
Bi-Flow console		RAS-B10U2FVG-E	10k
		RAS-B13U2FVG-E	13k

2. Specifications

2.1 Outdoor unit : RAS-2M14U2AVG-E

Unit model	Outdoor		RAS-	2M14U2AVG-E	
	Connection indoor unit of this specification		RAS-	B13PKVSG-E (×2)	
Cooling Capacity (*1)			(kW)	4.0	
Cooling Capacity range			(kW)	1.6 to 4.9	
Heating Capacity (*1)			(kW)	4.4	
Heating Capacity range			(kW)	1.3 to 5.2	
-7°C Max heating			(kW)	2.74	
Power supply				1Ph,220-240V,50Hz	
Electric characteristics	Total	Operation mode		Cooling	Heating
		Running current	(A)	4.55 / 4.35 / 4.15	4.40 / 4.20 / 4.05
		Power consumption	(W)	920	890
		Power factor	(%)	92	92
		Starting current	(A)	4.55 / 4.35 / 4.15	
EER / COP				4.35 / 4.94	
SEER / SCOP				6.73 / 4.60	
Operating noise	Outdoor (Cooling/Heating)	Sound pressure level	(dBA)	45 / 46	
		Sound power level	(dBA)	58 / 59	
Outdoor unit	Dimension	Height	(mm)	630	
		Width	(mm)	800	
		Depth	(mm)	300	
	Net weight		(kg)	43	
	Compressor	Motor output	(W)	1050	
		Type		Single rotary type with DC-inverter variable speed control	
		Model		KTN130D3UFZ	
	Fan motor output		(W)	43	
	Air flow rate (Cooling/Heating)		(m³/h)	1863 / 1863	
	Type			Flare connection	
	Name of refirigerant			R32	
	Weight of refigerant		(kg)	1.02	
Piping connection	Outdoor unit	A unit liquid side/gas side		Ø6.35 / Ø9.52	
		B unit liquid side/gas side		Ø6.35 / Ø9.52	
		C unit liquid side/gas side		-	
	Maximum length (per unit)		(m)	20	
	Maximum length (total)		(m)	30	
	Maximum chargeless length		(m)	30	
	Maximum height difference		(m)	10	
Wiring connection	Power supply / interconnection			3 Wires : includes earth / 4 Wires : includes earth	
Usable temperature range	Outdoor (Cooling/Heating)		(℃)	-10 to 46℃ / -20 to 24℃	
Accessory Outdoor unit	Installation manual			1	

- For performance when each indoor unit is combined with other unit, refer to the separate table.
- The specifications may be subject to change without notice for purpose of improvement.
- (*1) Rated conditions
  Cooling : Capacity test condition, inside : 27 °C (Db) / 19 °C (Wb), outside : 35 °C (Db) / 24 °C (Wb)
  Heating : Capacity test condition, inside : 20 °C (Db), outside : 7 °C (Db) / 6°C (Wb)
  Piping length : 5 m per Indoor Unit.

2.2 Combination

Operation mode : Cooling

Power supply voltage : 220V

Operating status	Indoor unit				Unit capacity (kW)			Total				
	A	B	C	ΣkBTU	A	B	C	Cooling capacity (kW)	Power consumption (W)	Operating current (A)	Power factor (%)	Rated SEER
1 unit	05	-	-	5	1.50	-	-	1.50 (1.20 - 1.80)	310 (240 - 380)	1.67 (1.52 - 1.89)	84 (72 - 92)	-
	07	-	-	7	2.00	-	-	2.00 (1.30 - 2.50)	420 (240 - 590)	2.25 (1.52 - 2.93)	85 (72 - 92)	-
	10	-	-	10	2.70	-	-	2.70 (1.30 - 3.20)	640 (240 - 860)	3.40 (1.52 - 4.20)	86 (72 - 93)	-
	13	-	-	13	3.70	-	-	3.70 (1.30 - 4.10)	1050 (240 - 1190)	5.49 (1.52 - 5.80)	87 (72 - 93)	-
2 units	05	05	-	10	1.50	1.50	-	3.00 (1.60 - 4.20)	910 (290 - 1130)	4.50 (1.84 - 5.45)	92 (72 - 94)	5.10
	07	05	-	12	2.00	1.50	-	3.50 (1.60 - 4.30)	960 (290 - 1130)	4.75 (1.84 - 5.45)	92 (72 - 94)	5.64
	10	05	-	15	2.57	1.43	-	4.00 (1.60 - 4.40)	1030 (290 - 1130)	5.12 (1.84 - 5.45)	92 (72 - 94)	6.01
	13	05	-	18	2.85	1.15	-	4.00 (1.60 - 4.50)	960 (290 - 1130)	4.75 (1.84 - 5.45)	92 (72 - 94)	6.45
	07	07	-	14	2.00	2.00	-	4.00 (1.60 - 4.50)	1030 (290 - 1130)	5.12 (1.84 - 5.45)	92 (72 - 94)	6.55
	10	07	-	17	2.30	1.70	-	4.00 (1.60 - 4.60)	960 (290 - 1130)	4.75 (1.84 - 5.45)	92 (72 - 94)	6.58
	13	07	-	20	2.60	1.40	-	4.00 (1.60 - 4.70)	940 (290 - 1140)	4.65 (1.84 - 5.50)	92 (72 - 94)	6.65
	10	10	-	20	2.00	2.00	-	4.00 (1.60 - 4.70)	940 (290 - 1140)	4.65 (1.84 - 5.50)	92 (72 - 94)	6.63
	13	10	-	23	2.31	1.69	-	4.00 (1.60 - 4.80)	930 (290 - 1150)	4.59 (1.84 - 5.55)	92 (72 - 94)	6.70
	13	13	-	26	2.00	2.00	-	4.00 (1.60 - 4.90)	920 (290 - 1150)	4.55 (1.84 - 5.55)	92 (72 - 94)	6.73

Power supply voltage : 230V

Operating status	Indoor unit				Unit capacity (kW)			Total				
	A	B	C	ΣkBTU	A	B	C	Cooling capacity (kW)	Power consumption (W)	Operating current (A)	Power factor (%)	Rated SEER
1 unit	05	-	-	5	1.50	-	-	1.50 (1.20 - 1.80)	310 (240 - 380)	1.60 (1.45 - 1.80)	84 (72 - 92)	-
	07	-	-	7	2.00	-	-	2.00 (1.30 - 2.50)	420 (240 - 590)	2.15 (1.45 - 2.80)	85 (72 - 92)	-
	10	-	-	10	2.70	-	-	2.70 (1.30 - 3.20)	640 (240 - 860)	3.25 (1.45 - 4.00)	86 (72 - 93)	-
	13	-	-	13	3.70	-	-	3.70 (1.30 - 4.10)	1050 (240 - 1190)	5.25 (1.45 - 5.55)	87 (72 - 93)	-
2 units	05	05	-	10	1.50	1.50	-	3.00 (1.60 - 4.20)	910 (290 - 1130)	4.30 (1.76 - 5.23)	92 (72 - 94)	5.10
	07	05	-	12	2.00	1.50	-	3.50 (1.60 - 4.30)	960 (290 - 1130)	4.55 (1.76 - 5.23)	92 (72 - 94)	5.64
	10	05	-	15	2.57	1.43	-	4.00 (1.60 - 4.40)	1030 (290 - 1130)	4.89 (1.76 - 5.23)	92 (72 - 94)	6.01
	13	05	-	18	2.85	1.15	-	4.00 (1.60 - 4.50)	960 (290 - 1130)	4.55 (1.76 - 5.23)	92 (72 - 94)	6.45
	07	07	-	14	2.00	2.00	-	4.00 (1.60 - 4.50)	1030 (290 - 1130)	4.89 (1.76 - 5.23)	92 (72 - 94)	6.55
	10	07	-	17	2.30	1.70	-	4.00 (1.60 - 4.60)	960 (290 - 1130)	4.55 (1.76 - 5.23)	92 (72 - 94)	6.58
	13	07	-	20	2.60	1.40	-	4.00 (1.60 - 4.70)	940 (290 - 1140)	4.45 (1.76 - 5.27)	92 (72 - 94)	6.65
	10	10	-	20	2.00	2.00	-	4.00 (1.60 - 4.70)	940 (290 - 1140)	4.45 (1.76 - 5.30)	92 (72 - 94)	6.63
	13	10	-	23	2.31	1.69	-	4.00 (1.60 - 4.80)	930 (290 - 1150)	4.40 (1.76 - 5.35)	92 (72 - 94)	6.70
	13	13	-	26	2.00	2.00	-	4.00 (1.60 - 4.90)	920 (290 - 1150)	4.35 (1.76 - 5.30)	92 (72 - 94)	6.73

Power supply voltage : 240V

Operating status	Indoor unit				Unit capacity (kW)			Total				
	A	B	C	ΣkBTU	A	B	C	Cooling capacity (kW)	Power consumption (W)	Operating current (A)	Power factor (%)	Rated SEER
1 unit	05	-	-	5	1.50	-	-	1.50 (1.20 - 1.80)	310 (240 - 380)	1.53 (1.40 - 1.73)	85 (72 - 92)	-
	07	-	-	7	2.00	-	-	2.00 (1.30 - 2.50)	420 (240 - 590)	2.05 (1.40 - 2.69)	85 (72 - 92)	-
	10	-	-	10	2.70	-	-	2.70 (1.30 - 3.20)	640 (240 - 860)	3.10 (1.40 - 3.85)	86 (72 - 93)	-
	13	-	-	13	3.70	-	-	3.70 (1.30 - 4.10)	1050 (240 - 1190)	5.05 (1.40 - 5.35)	87 (72 - 93)	-
2 units	05	05	-	10	1.50	1.50	-	3.00 (1.60 - 4.20)	910 (290 - 1130)	4.12 (1.68 - 5.01)	92 (72 - 94)	5.10
	07	05	-	12	2.00	1.50	-	3.50 (1.60 - 4.30)	960 (290 - 1130)	4.35 (1.68 - 5.00)	92 (72 - 94)	5.64
	10	05	-	15	2.57	1.43	-	4.00 (1.60 - 4.40)	1030 (290 - 1130)	4.69 (1.68 - 5.00)	92 (72 - 94)	6.01
	13	05	-	18	2.85	1.15	-	4.00 (1.60 - 4.50)	960 (290 - 1130)	4.36 (1.68 - 5.00)	92 (72 - 94)	6.45
	07	07	-	14	2.00	2.00	-	4.00 (1.60 - 4.50)	1030 (290 - 1130)	4.69 (1.68 - 5.00)	92 (72 - 94)	6.55
	10	07	-	17	2.30	1.70	-	4.00 (1.60 - 4.60)	960 (290 - 1130)	4.36 (1.68 - 5.00)	92 (72 - 94)	6.58
	13	07	-	20	2.60	1.40	-	4.00 (1.60 - 4.70)	940 (290 - 1140)	4.27 (1.68 - 5.05)	92 (72 - 94)	6.65
	10	10	-	20	2.00	2.00	-	4.00 (1.60 - 4.70)	940 (290 - 1140)	4.27 (1.68 - 5.05)	92 (72 - 94)	6.63
	13	10	-	23	2.31	1.69	-	4.00 (1.60 - 4.80)	930 (290 - 1150)	4.21 (1.68 - 5.10)	92 (72 - 94)	6.70
	13	13	-	26	2.00	2.00	-	4.00 (1.60 - 4.90)	920 (290 - 1150)	4.15 (1.68 - 5.10)	92 (72 - 94)	6.73

• Specification values are those under the condition as follows ;
Cooling : Capacity test condition, inside : 27 °C (Db) / 19 °C (Wb), outside : 35 °C (Db) / 24 °C (Wb)
Piping length : 5 m per Indoor Unit.

Operation mode : Heating

Power supply voltage : 220V

Operating status	Indoor unit				Unit capacity (kW)			Total				
	A	B	C	ΣkBTU	A	B	C	Heating capacity (kW)	Power consumption (W)	Operating current (A)	Power factor (%)	Rated SCOP
1 unit	05	-	-	5	2.00	-	-	2.0 (0.9 - 2.5)	440 (190 - 580)	2.40 (1.20 - 2.88)	84 (72 - 92)	-
	07	-	-	7	2.70	-	-	2.7 (0.9 - 3.4)	610 (190 - 820)	3.30 (1.20 - 4.07)	84 (72 - 92)	-
	10	-	-	10	4.00	-	-	4.0 (0.9 - 4.8)	1050 (190 - 1380)	5.60 (1.20 - 6.75)	85 (72 - 93)	-
	13	-	-	13	4.40	-	-	4.4 (1.0 - 5.2)	1350 (210 - 1410)	7.14 (1.33 - 6.90)	86 (72 - 93)	-
2 units	05	05	-	10	2.00	2.00	-	4.0 (1.3 - 4.7)	920 (250 - 1270)	4.55 (1.58 - 6.15)	92 (72 - 94)	3.82
	07	05	-	12	2.70	2.00	-	4.4 (1.3 - 4.8)	960 (250 - 1270)	4.74 (1.58 - 6.15)	92 (72 - 94)	4.09
	10	05	-	15	3.73	1.87	-	4.4 (1.3 - 4.9)	960 (250 - 1270)	4.74 (1.58 - 6.15)	92 (72 - 94)	4.09
	13	05	-	18	4.00	1.60	-	4.4 (1.3 - 5.0)	950 (250 - 1250)	4.69 (1.58 - 6.05)	92 (72 - 94)	4.13
	07	07	-	14	2.70	2.70	-	4.4 (1.3 - 5.1)	960 (250 - 1270)	4.74 (1.58 - 6.15)	92 (72 - 94)	4.31
	10	07	-	17	3.34	2.26	-	4.4 (1.3 - 5.1)	950 (250 - 1250)	4.69 (1.58 - 6.05)	92 (72 - 94)	4.33
	13	07	-	20	3.64	1.96	-	4.4 (1.3 - 5.2)	920 (250 - 1250)	4.55 (1.58 - 6.05)	92 (72 - 94)	4.37
	10	10	-	20	2.80	2.80	-	4.4 (1.3 - 5.1)	930 (250 - 1230)	4.59 (1.58 - 5.95)	92 (72 - 94)	4.35
	13	10	-	23	2.30	2.10	-	4.4 (1.3 - 5.2)	910 (250 - 1230)	4.50 (1.58 - 5.95)	92 (72 - 94)	4.39
	13	13	-	26	2.20	2.20	-	4.4 (1.3 - 5.2)	890 (250 - 1220)	4.40 (1.52 - 5.90)	92 (75 - 94)	4.60

Power supply voltage : 230V

Operating status	Indoor unit				Unit capacity (kW)			Total				
	A	B	C	ΣkBTU	A	B	C	Heating capacity (kW)	Power consumption (W)	Operating current (A)	Power factor (%)	Rated SCOP
1 unit	05	-	-	5	2.00	-	-	2.0 (0.9 - 2.5)	440 (190 - 580)	2.28 (1.15 - 2.75)	84 (72 - 92)	-
	07	-	-	7	2.70	-	-	2.7 (0.9 - 3.4)	610 (190 - 820)	3.16 (1.15 - 3.90)	84 (72 - 92)	-
	10	-	-	10	4.00	-	-	4.0 (0.9 - 4.8)	1050 (190 - 1380)	5.37 (1.15 - 6.45)	85 (72 - 93)	-
	13	-	-	13	4.40	-	-	4.4 (1.0 - 5.2)	1350 (210 - 1410)	6.83 (1.27 - 6.61)	86 (72 - 93)	-
2 units	05	05	-	10	2.00	2.00	-	4.0 (1.3 - 4.7)	920 (250 - 1270)	4.34 (1.52 - 5.90)	92 (72 - 94)	3.82
	07	05	-	12	2.70	2.00	-	4.4 (1.3 - 4.8)	960 (250 - 1270)	4.53 (1.52 - 5.90)	92 (72 - 94)	4.09
	10	05	-	15	3.73	1.87	-	4.4 (1.3 - 4.9)	960 (250 - 1270)	4.53 (1.52 - 5.90)	92 (72 - 94)	4.09
	13	05	-	18	4.00	1.60	-	4.4 (1.3 - 5.0)	950 (250 - 1250)	4.48 (1.52 - 5.81)	92 (72 - 94)	4.13
	07	07	-	14	2.70	2.70	-	4.4 (1.3 - 5.1)	960 (250 - 1270)	4.53 (1.52 - 5.90)	92 (72 - 94)	4.31
	10	07	-	17	3.34	2.26	-	4.4 (1.3 - 5.1)	950 (250 - 1250)	4.48 (1.52 - 5.81)	92 (72 - 94)	4.33
	13	07	-	20	3.64	1.96	-	4.4 (1.3 - 5.2)	920 (250 - 1250)	4.34 (1.52 - 5.81)	92 (72 - 94)	4.37
	10	10	-	20	2.80	2.80	-	4.4 (1.3 - 5.1)	930 (250 - 1230)	4.39 (1.52 - 5.71)	92 (72 - 94)	4.35
	13	10	-	23	2.30	2.10	-	4.4 (1.3 - 5.2)	910 (250 - 1230)	4.29 (1.52 - 5.71)	92 (72 - 94)	4.39
	13	13	-	26	2.20	2.20	-	4.4 (1.3 - 5.2)	890 (250 - 1220)	4.20 (1.52 - 5.65)	92 (72 - 94)	4.60

Power supply voltage : 240V

Operating status	Indoor unit				Unit capacity (kW)			Total				
								Heating capacity (kW)	Power consumption (W)	Operating current (A)	Power factor (%)	Rated SCOP
	A	B	C	ΣkBTU	A	B	C					
1 unit	05	-	-	5	2.00	-	-	2.0 (0.9 - 2.5)	440 (190 - 580)	2.20 (1.10 - 2.64)	84 (72 - 92)	-
	07	-	-	7	2.70	-	-	2.7 (0.9 - 3.4)	610 (190 - 820)	3.04 (1.10 - 3.73)	84 (72 - 92)	-
	10	-	-	10	4.00	-	-	4.0 (0.9 - 4.8)	1050 (190 - 1380)	5.15 (1.10 - 6.20)	85 (72 - 93)	-
	13	-	-	13	4.40	-	-	4.4 (1.0 - 5.2)	1350 (210 - 1410)	6.55 (1.22 - 6.33)	86 (72 - 93)	-
2 units	05	05	-	10	2.00	2.00	-	4.0 (1.3 - 4.7)	920 (250 - 1270)	4.17 (1.45 - 5.65)	92 (72 - 94)	3.82
	07	05	-	12	2.70	2.00	-	4.4 (1.3 - 4.8)	960 (250 - 1270)	4.35 (1.45 - 5.65)	92 (72 - 94)	4.09
	10	05	-	15	3.73	1.87	-	4.4 (1.3 - 4.9)	960 (250 - 1270)	4.35 (1.45 - 5.65)	92 (72 - 94)	4.09
	13	05	-	18	4.00	1.60	-	4.4 (1.3 - 5.0)	950 (250 - 1250)	4.30 (1.45 - 5.56)	92 (72 - 94)	4.13
	07	07	-	14	2.70	2.70	-	4.4 (1.3 - 5.1)	960 (250 - 1270)	4.35 (1.45 - 5.65)	92 (72 - 94)	4.31
	10	07	-	17	3.34	2.26	-	4.4 (1.3 - 5.1)	950 (250 - 1250)	4.30 (1.45 - 5.56)	92 (72 - 94)	4.33
	13	07	-	20	3.64	1.96	-	4.4 (1.3 - 5.2)	920 (250 - 1250)	4.17 (1.45 - 5.56)	92 (72 - 94)	4.37
	10	10	-	20	2.80	2.80	-	4.4 (1.3 - 5.1)	930 (250 - 1230)	4.21 (1.45 - 5.48)	92 (72 - 94)	4.35
	13	10	-	23	2.30	2.10	-	4.4 (1.3 - 5.2)	910 (250 - 1230)	4.12 (1.45 - 5.48)	92 (72 - 94)	4.39
	13	13	-	26	2.20	2.20	-	4.4	890	4.05	92	4.60

• Specification values are those under the condition as follows ;
Heating : Capacity test condition, inside : 20 °C (Db), outside : 7 °C (Db) / 6°C (Wb)
Piping length : 5 m per Indoor Unit.

3. Cooling / Heating Capacity Characteristic

Connecting pipe length and lift difference between indoor units vs. capacity correction value.

Capacity variation ratio according to outdoor temperature

<Cooling>
RAS-2M14U2AVG-E



<Heating>
RAS-2M14U2AVG-E



Capacity variation ratio according to pipe length

<Cooling>
RAS-2M14U2AVG-E



<Heating>
RAS-2M14U2AVG-E



4. Dimension

RAS-2M14U2AVG-E

Diameter of pipe connecting port			
	Unit B	Liquid side	Φ6.35
		Gas side	Φ9.52
	Unit A	Liquid side	Φ6.35
		Gas side	Φ9.52
Model name			RAS-2M10U2AVG-E



5. Wiring diagrams

RAS-2M14U2AVG-E



Symbol	Part name
PMV	PULSE MOTOR VALVE
TD	DISCHARGE PIPE TEMP. SENSOR
TE	CONDENSER PIPE TEMP. SENSOR
TO	OUTDOOR TEMP. SENSOR
TS	SUCTION PIPE TEMP. SENSOR
TGa, TGb	GAS SIDE PIPE TEMP. SENSOR a, b
L/F	LINE FILTER
F-IUa, F-IUb	PROTECTION CONNECTING FUSE a, b

6. REFRIGERANT CYCLE DIAGRAM

RAS-2M14U2AVG-E



NOTE :

- You need not add refrigerant if the piping length is 20m or less.
- Connection of only one indoor unit is unavailable. Two indoor units should be connected.

7. Sound Characteristics (NC Curve)

RES-2M14U2AVG-E

Cooling

Specification (d B)	
Fan tap	Cooling
Sound pressure level (dB(A))	45



Heating

Specification (d B)	
Fan tap	Heating
Sound pressure level (dB(A))	46



8. Capacity table

Cooling

2 - room multisplit : 1 - unit operation

Indoor units : 05 type
07 type
10 type
13 type

Outdoor unit : RAS-2M14U2AVG-E

Combination Capacity	Outdoor air temp [°C DB]	Indoor air temp [°C DB/WB]											
		20.0 °C DB. / 14.0 °C WB.		23.0 °C DB. / 16.0 °C WB.		26.0 °C DB. / 18.0 °C WB.		27.0 °C DB. / 19.0 °C WB.		30.0 °C DB. / 22.0 °C WB.		32.0 °C DB. / 24.0 °C WB.	
		TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]
05	46	1.12	0.35	1.17	0.36	1.23	0.36	**1.26**	**0.37**	1.35	0.38	1.40	0.39
	43	1.19	0.33	1.26	0.34	1.32	0.34	**1.35**	**0.35**	1.44	0.36	1.51	0.37
	40	1.24	0.31	1.30	0.32	1.37	0.32	**1.40**	**0.33**	1.50	0.34	1.56	0.35
	35	1.33	0.29	1.40	0.30	1.46	0.30	**1.50**	**0.31**	1.61	0.32	1.67	0.33
	32	1.42	0.28	1.49	0.28	1.56	0.28	**1.60**	**0.29**	1.71	0.30	1.78	0.30
	25	1.50	0.26	1.57	0.26	1.65	0.26	**1.69**	**0.27**	1.81	0.28	1.88	0.28
	22	1.58	0.23	1.66	0.23	1.75	0.23	**1.79**	**0.24**	1.92	0.25	2.00	0.25
07	46	1.49	0.48	1.56	0.49	1.64	0.49	**1.68**	**0.50**	1.80	0.51	1.87	0.53
	43	1.58	0.45	1.66	0.46	1.75	0.46	**1.79**	**0.47**	1.92	0.48	2.00	0.49
	40	1.65	0.43	1.74	0.44	1.82	0.44	**1.87**	**0.45**	2.00	0.46	2.09	0.47
	35	1.77	0.40	1.86	0.41	1.95	0.41	**2.00**	**0.42**	2.14	0.43	2.23	0.44
	32	1.89	0.37	1.98	0.38	2.08	0.38	**2.13**	**0.39**	2.28	0.40	2.37	0.41
	25	2.00	0.34	2.10	0.35	2.20	0.35	**2.26**	**0.36**	2.42	0.37	2.52	0.38
	22	2.12	0.31	2.22	0.32	2.33	0.32	**2.39**	**0.33**	2.56	0.34	2.66	0.35
10	46	2.01	0.73	2.11	0.75	2.21	0.75	**2.27**	**0.77**	2.43	0.79	2.53	0.81
	43	2.14	0.67	2.25	0.69	2.36	0.69	**2.42**	**0.71**	2.59	0.73	2.70	0.75
	40	2.24	0.66	2.35	0.67	2.47	0.67	**2.53**	**0.69**	2.71	0.71	2.82	0.72
	35	2.39	0.61	2.51	0.62	2.63	0.62	**2.70**	**0.64**	2.89	0.66	3.01	0.67
	32	2.54	0.56	2.67	0.58	2.80	0.58	**2.87**	**0.59**	3.07	0.60	3.20	0.62
	25	2.70	0.52	2.84	0.54	2.97	0.54	**3.05**	**0.55**	3.26	0.56	3.40	0.58
	22	2.85	0.48	2.99	0.49	3.14	0.49	**3.22**	**0.50**	3.45	0.51	3.59	0.53
13	46	2.74	1.20	2.88	1.23	3.02	1.23	**3.10**	**1.26**	3.32	1.29	3.46	1.32
	43	2.94	1.11	3.09	1.14	3.24	1.14	**3.32**	**1.17**	3.55	1.20	3.70	1.23
	40	3.06	1.07	3.22	1.10	3.37	1.10	**3.46**	**1.13**	3.70	1.16	3.86	1.19
	35	3.27	1.00	3.44	1.02	3.61	1.02	**3.70**	**1.05**	3.96	1.08	4.13	1.10
	32	3.49	0.92	3.66	0.95	3.84	0.95	**3.94**	**0.97**	4.22	0.99	4.39	1.02
	25	3.69	0.86	3.88	0.88	4.07	0.88	**4.17**	**0.90**	4.46	0.92	4.65	0.95
	22	3.90	0.78	4.10	0.80	4.30	0.80	**4.41**	**0.82**	4.72	0.84	4.92	0.86

TC : Total capacity [kW]
PI ; Power input [kW]

Cooling

2 - room multisplit : 2 - unit operation

Indoor units : **05 type + 05 type** **10 type + 07 type**
07 type + 05 type **13 type + 07 type**
10 type + 05 type **10 type + 10 type**
13 type + 05 type **13 type + 10 type**
07 type + 07 type **13 type + 13 type**

Outdoor unit : **RAS-2M14U2AVG-E**

Combination Capacity	Outdoor air temp [°C DB]	Indoor air temp [°C DB/WB]											
		20.0 °C DB. / 14.0 °C WB.		23.0 °C DB. / 16.0 °C WB.		26.0 °C DB. / 18.0 °C WB.		27.0 °C DB. / 19.0 °C WB.		30.0 °C DB. / 22.0 °C WB.		32.0 °C DB. / 24.0 °C WB.	
		TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]
05+05	46	2.52	1.09	2.52	1.09	2.52	1.09	**2.52**	**1.09**	2.52	1.09	2.52	1.09
	43	2.69	1.01	2.69	1.01	2.69	1.01	**2.69**	**1.01**	2.69	1.01	2.69	1.01
	40	2.81	0.98	2.81	0.98	2.81	0.98	**2.81**	**0.98**	2.81	0.98	2.81	0.98
	35	3.00	0.91	3.00	0.91	3.00	0.91	**3.00**	**0.91**	3.00	0.91	3.00	0.91
	32	3.19	0.84	3.19	0.84	3.19	0.84	**3.19**	**0.84**	3.19	0.84	3.19	0.84
	25	3.39	0.78	3.39	0.78	3.39	0.78	**3.39**	**0.78**	3.39	0.78	3.39	0.78
	22	3.58	0.71	3.58	0.71	3.58	0.71	**3.58**	**0.71**	3.58	0.71	3.58	0.71
07+05	46	2.94	1.15	2.94	1.15	2.94	1.15	**2.94**	**1.15**	2.94	1.15	2.94	1.15
	43	3.14	1.07	3.14	1.07	3.14	1.07	**3.14**	**1.07**	3.14	1.07	3.14	1.07
	40	3.28	1.03	3.28	1.03	3.28	1.03	**3.28**	**1.03**	3.28	1.03	3.28	1.03
	35	3.50	0.96	3.50	0.96	3.50	0.96	**3.50**	**0.96**	3.50	0.96	3.50	0.96
	32	3.72	0.89	3.72	0.89	3.72	0.89	**3.72**	**0.89**	3.72	0.89	3.72	0.89
	25	3.95	0.82	3.95	0.82	3.95	0.82	**3.95**	**0.82**	3.95	0.82	3.95	0.82
	22	4.17	0.75	4.17	0.75	4.17	0.75	**4.17**	**0.75**	4.17	0.75	4.17	0.75
10+05	46	3.36	1.23	3.36	1.23	3.36	1.23	**3.36**	**1.23**	3.36	1.23	3.36	1.23
	43	3.59	1.15	3.59	1.15	3.59	1.15	**3.59**	**1.15**	3.59	1.15	3.59	1.15
	40	3.74	1.10	3.74	1.10	3.74	1.10	**3.74**	**1.10**	3.74	1.10	3.74	1.10
	35	4.00	1.03	4.00	1.03	4.00	1.03	**4.00**	**1.03**	4.00	1.03	4.00	1.03
	32	4.26	0.96	4.26	0.96	4.26	0.96	**4.26**	**0.96**	4.26	0.96	4.26	0.96
	25	4.51	0.88	4.51	0.88	4.51	0.88	**4.51**	**0.88**	4.51	0.88	4.51	0.88
	22	4.77	0.81	4.77	0.81	4.77	0.81	**4.77**	**0.81**	4.77	0.81	4.77	0.81
13+05	46	3.36	1.15	3.36	1.15	3.36	1.15	**3.36**	**1.15**	3.36	1.15	3.36	1.15
	43	3.59	1.07	3.59	1.07	3.59	1.07	**3.59**	**1.07**	3.59	1.07	3.59	1.07
	40	3.74	1.03	3.74	1.03	3.74	1.03	**3.74**	**1.03**	3.74	1.03	3.74	1.03
	35	4.00	0.96	4.00	0.96	4.00	0.96	**4.00**	**0.96**	4.00	0.96	4.00	0.96
	32	4.26	0.89	4.26	0.89	4.26	0.89	**4.26**	**0.89**	4.26	0.89	4.26	0.89
	25	4.51	0.82	4.51	0.82	4.51	0.82	**4.51**	**0.82**	4.51	0.82	4.51	0.82
	22	4.77	0.75	4.77	0.75	4.77	0.75	**4.77**	**0.75**	4.77	0.75	4.77	0.75
07+07	46	3.36	1.23	3.36	1.23	3.36	1.23	**3.36**	**1.23**	3.36	1.23	3.36	1.23
	43	3.59	1.15	3.59	1.15	3.59	1.15	**3.59**	**1.15**	3.59	1.15	3.59	1.15
	40	3.74	1.10	3.74	1.10	3.74	1.10	**3.74**	**1.10**	3.74	1.10	3.74	1.10
	35	4.00	1.03	4.00	1.03	4.00	1.03	**4.00**	**1.03**	4.00	1.03	4.00	1.03
	32	4.26	0.96	4.26	0.96	4.26	0.96	**4.26**	**0.96**	4.26	0.96	4.26	0.96
	25	4.51	0.88	4.51	0.88	4.51	0.88	**4.51**	**0.88**	4.51	0.88	4.51	0.88
	22	4.77	0.81	4.77	0.81	4.77	0.81	**4.77**	**0.81**	4.77	0.81	4.77	0.81
10+07	46	3.36	1.15	3.36	1.15	3.36	1.15	**3.36**	**1.15**	3.36	1.15	3.36	1.15
	43	3.59	1.07	3.59	1.07	3.59	1.07	**3.59**	**1.07**	3.59	1.07	3.59	1.07
	40	3.74	1.03	3.74	1.03	3.74	1.03	**3.74**	**1.03**	3.74	1.03	3.74	1.03
	35	4.00	0.96	4.00	0.96	4.00	0.96	**4.00**	**0.96**	4.00	0.96	4.00	0.96
	32	4.26	0.89	4.26	0.89	4.26	0.89	**4.26**	**0.89**	4.26	0.89	4.26	0.89
	25	4.51	0.82	4.51	0.82	4.51	0.82	**4.51**	**0.82**	4.51	0.82	4.51	0.82
	22	4.77	0.75	4.77	0.75	4.77	0.75	**4.77**	**0.75**	4.77	0.75	4.77	0.75
13+07	46	0.00	1.13	3.36	1.13	3.36	1.13	**3.36**	**1.13**	3.36	1.13	3.36	1.13
	43	3.59	1.05	3.59	1.05	3.59	1.05	**3.59**	**1.05**	3.59	1.05	3.59	1.05
	40	3.74	1.01	3.74	1.01	3.74	1.01	**3.74**	**1.01**	3.74	1.01	3.74	1.01
	35	4.00	0.94	4.00	0.94	4.00	0.94	**4.00**	**0.94**	4.00	0.94	4.00	0.94
	32	4.26	0.87	4.26	0.87	4.26	0.87	**4.26**	**0.87**	4.26	0.87	4.26	0.87
	25	4.51	0.81	4.51	0.81	4.51	0.81	**4.51**	**0.81**	4.51	0.81	4.51	0.81
	22	4.77	0.74	4.77	0.74	4.77	0.74	**4.77**	**0.74**	4.77	0.74	4.77	0.74
10+10	46	3.36	1.13	3.36	1.13	3.36	1.13	**3.36**	**1.13**	3.36	1.13	3.36	1.13
	43	3.59	1.05	3.59	1.05	3.59	1.05	**3.59**	**1.05**	3.59	1.05	3.59	1.05
	40	3.74	1.01	3.74	1.01	3.74	1.01	**3.74**	**1.01**	3.74	1.01	3.74	1.01
	35	4.00	0.94	4.00	0.94	4.00	0.94	**4.00**	**0.94**	4.00	0.94	4.00	0.94
	32	4.26	0.87	4.26	0.87	4.26	0.87	**4.26**	**0.87**	4.26	0.87	4.26	0.87
	25	4.51	0.81	4.51	0.81	4.51	0.81	**4.51**	**0.81**	4.51	0.81	4.51	0.81
	22	4.77	0.74	4.77	0.74	4.77	0.74	**4.77**	**0.74**	4.77	0.74	4.77	0.74
13+10	46	3.36	1.11	3.36	1.11	3.36	1.11	**3.36**	**1.11**	3.36	1.11	3.36	1.11
	43	3.59	1.04	3.59	1.04	3.59	1.04	**3.59**	**1.04**	3.59	1.04	3.59	1.04
	40	3.74	1.00	3.74	1.00	3.74	1.00	**3.74**	**1.00**	3.74	1.00	3.74	1.00
	35	4.00	0.93	4.00	0.93	4.00	0.93	**4.00**	**0.93**	4.00	0.93	4.00	0.93
	32	4.26	0.86	4.26	0.86	4.26	0.86	**4.26**	**0.86**	4.26	0.86	4.26	0.86
	25	4.51	0.80	4.51	0.80	4.51	0.80	**4.51**	**0.80**	4.51	0.80	4.51	0.80
	22	4.77	0.73	4.77	0.73	4.77	0.73	**4.77**	**0.73**	4.77	0.73	4.77	0.73
13+13	46	3.36	1.10	3.36	1.10	3.36	1.10	**3.36**	**1.10**	3.36	1.10	3.36	1.10
	43	3.59	1.03	3.59	1.03	3.59	1.03	**3.59**	**1.03**	3.59	1.03	3.59	1.03
	40	3.74	0.99	3.74	0.99	3.74	0.99	**3.74**	**0.99**	3.74	0.99	3.74	0.99
	35	4.00	0.92	4.00	0.92	4.00	0.92	**4.00**	**0.92**	4.00	0.92	4.00	0.92
	32	4.26	0.85	4.26	0.85	4.26	0.85	**4.26**	**0.85**	4.26	0.85	4.26	0.85
	25	4.51	0.79	4.51	0.79	4.51	0.79	**4.51**	**0.79**	4.51	0.79	4.51	0.79
	22	4.77	0.72	4.77	0.72	4.77	0.72	**4.77**	**0.72**	4.77	0.72	4.77	0.72

TC : Total capacity [kW]
PI ; Power input [kW]

Heating

2 - room multisplit : 1 - unit operation

Indoor units : 05 type
07 type
10 type
13 type

Outdoor unit : RAS-2M14U2AVG-E

Combination Capacity	Outdoor air temp [°C WB]	Indoor air temp [°C DB]											
		16.0 °C DB		18.0 °C DB		20.0 °C DB		21.0 °C DB.		22.0 °C DB		24.0 °C DB	
		TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]
05	20	2.58	0.47	2.55	0.47	**2.51**	**0.48**	2.49	0.48	2.47	0.48	2.44	0.49
	15	2.38	0.46	2.35	0.46	**2.32**	**0.47**	2.30	0.47	2.29	0.47	2.25	0.48
	10	2.17	0.44	2.15	0.44	**2.12**	**0.45**	2.10	0.45	2.09	0.45	2.06	0.46
	7	2.05	0.43	2.03	0.43	**2.00**	**0.44**	1.99	0.44	1.97	0.44	1.94	0.45
	5.5	1.75	0.40	1.74	0.40	**1.71**	**0.41**	1.70	0.41	1.68	0.41	1.66	0.42
	5	1.65	0.40	1.63	0.40	**1.61**	**0.41**	1.60	0.41	1.59	0.41	1.56	0.42
	2	1.50	0.38	1.48	0.39	**1.46**	**0.39**	1.45	0.39	1.44	0.39	1.42	0.40
	0	1.40	0.37	1.38	0.38	**1.36**	**0.38**	1.35	0.38	1.34	0.38	1.32	0.39
	-5	1.13	0.34	1.12	0.35	**1.10**	**0.35**	1.09	0.35	1.08	0.35	1.07	0.36
	-7	1.03	0.33	1.01	0.34	**1.00**	**0.34**	0.99	0.34	0.99	0.34	0.97	0.35
	-10	1.08	0.34	1.07	0.35	**1.05**	**0.35**	1.04	0.35	1.03	0.35	1.02	0.36
	-15	0.88	0.33	0.87	0.34	**0.86**	**0.34**	0.85	0.34	0.85	0.34	0.83	0.35
	-20	0.57	0.30	0.57	0.30	**0.56**	**0.30**	0.56	0.30	0.55	0.30	0.54	0.30
07	20	3.48	0.66	3.44	0.66	**3.39**	**0.67**	3.36	0.67	3.34	0.67	3.29	0.68
	15	3.21	0.64	3.18	0.64	**3.13**	**0.65**	3.11	0.65	3.08	0.65	3.04	0.66
	10	2.93	0.61	2.90	0.61	**2.86**	**0.62**	2.84	0.62	2.82	0.62	2.78	0.63
	7	2.77	0.60	2.74	0.60	**2.70**	**0.61**	2.68	0.61	2.66	0.61	2.62	0.62
	5.5	2.36	0.56	2.33	0.56	**2.30**	**0.57**	2.28	0.57	2.27	0.57	2.23	0.58
	5	2.22	0.56	2.19	0.56	**2.16**	**0.57**	2.14	0.57	2.13	0.57	2.10	0.58
	2	2.01	0.53	1.99	0.53	**1.96**	**0.54**	1.95	0.54	1.93	0.54	1.90	0.55
	0	1.87	0.52	1.85	0.52	**1.82**	**0.53**	1.81	0.53	1.79	0.53	1.77	0.54
	-5	1.52	0.48	1.50	0.48	**1.48**	**0.49**	1.47	0.49	1.46	0.49	1.44	0.50
	-7	1.39	0.46	1.37	0.46	**1.35**	**0.47**	1.34	0.47	1.33	0.47	1.31	0.48
	-10	1.46	0.48	1.44	0.48	**1.42**	**0.49**	1.41	0.49	1.40	0.49	1.38	0.50
	-15	1.19	0.46	1.18	0.46	**1.16**	**0.47**	1.15	0.47	1.14	0.47	1.13	0.48
	-20	0.78	0.40	0.77	0.40	**0.76**	**0.41**	0.75	0.41	0.75	0.41	0.74	0.42
10	20	5.16	1.14	5.10	1.15	**5.03**	**1.16**	4.99	1.16	4.96	1.17	4.88	1.18
	15	4.75	1.10	4.70	1.11	**4.63**	**1.12**	4.60	1.12	4.56	1.13	4.49	1.14
	10	4.35	1.05	4.30	1.06	**4.24**	**1.07**	4.21	1.07	4.18	1.08	4.11	1.09
	7	4.10	1.03	4.06	1.04	**4.00**	**1.05**	3.97	1.05	3.94	1.06	3.88	1.07
	5.5	3.50	0.96	3.46	0.97	**3.41**	**0.98**	3.38	0.98	3.36	0.99	3.31	1.00
	5	3.29	0.95	3.26	0.96	**3.21**	**0.97**	3.19	0.97	3.16	0.97	3.11	0.99
	2	2.99	0.92	2.95	0.92	**2.91**	**0.93**	2.89	0.93	2.87	0.93	2.82	0.95
	0	2.77	0.90	2.74	0.90	**2.70**	**0.91**	2.68	0.91	2.66	0.91	2.62	0.92
	-5	2.26	0.83	2.23	0.83	**2.20**	**0.84**	2.18	0.84	2.17	0.84	2.13	0.85
	-7	2.05	0.80	2.03	0.80	**2.00**	**0.81**	1.99	0.81	1.97	0.81	1.94	0.82
	-10	2.16	0.84	2.14	0.84	**2.11**	**0.85**	2.09	0.85	2.08	0.85	2.05	0.86
	-15	1.75	0.79	1.74	0.79	**1.71**	**0.80**	1.70	0.80	1.68	0.80	1.66	0.81
	-20	1.15	0.70	1.14	0.70	**1.12**	**0.71**	1.11	0.71	1.10	0.71	1.09	0.72
13	20	5.67	1.47	5.61	1.47	**5.53**	**1.49**	5.49	1.49	5.45	1.50	5.37	1.51
	15	5.23	1.41	5.18	1.41	**5.10**	**1.43**	5.06	1.43	5.02	1.44	4.95	1.45
	10	4.78	1.36	4.73	1.36	**4.66**	**1.38**	4.63	1.38	4.59	1.39	4.52	1.40
	7	4.51	1.33	4.47	1.33	**4.40**	**1.35**	4.37	1.35	4.33	1.36	4.27	1.37
	5.5	3.85	1.24	3.81	1.24	**3.75**	**1.26**	3.72	1.26	3.69	1.27	3.64	1.28
	5	3.62	1.23	3.58	1.23	**3.53**	**1.25**	3.50	1.25	3.48	1.26	3.43	1.27
	2	3.28	1.18	3.25	1.19	**3.20**	**1.20**	3.18	1.20	3.15	1.21	3.11	1.22
	0	3.05	1.15	3.01	1.16	**2.97**	**1.17**	2.95	1.17	2.93	1.18	2.88	1.19
	-5	2.48	1.06	2.46	1.07	**2.42**	**1.08**	2.40	1.08	2.38	1.09	2.35	1.10
	-7	2.26	1.02	2.23	1.03	**2.20**	**1.04**	2.18	1.04	2.17	1.05	2.13	1.06
	-10	2.38	1.07	2.35	1.08	**2.32**	**1.09**	2.30	1.09	2.29	1.10	2.25	1.11
	-15	1.93	1.01	1.91	1.02	**1.88**	**1.03**	1.87	1.03	1.85	1.04	1.82	1.05
	-20	1.26	0.91	1.25	0.91	**1.23**	**0.92**	1.22	0.92	1.21	0.92	1.19	0.93

TC : Total capacity [kW]
PI ; Power input [kW]

Heating

2 - room multisplit : 2 - unit operation

Indoor units : 05 type + 05 type
07 type + 05 type
10 type + 05 type
13 type + 05 type
07 type + 07 type

Outdoor unit : RAS-2M14U2AVG-E

Combination Capacity	Outdoor air temp [°C WB]	Indoor air temp [°C DB]											
		16.0 °C DB		18.0 °C DB		20.0 °C DB		21.0 °C DB.		22.0 °C DB		24.0 °C DB	
		TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]
05+05	20	5.16	1.08	5.10	1.09	**5.03**	**1.10**	4.99	1.10	4.96	1.11	4.88	1.12
	15	4.75	0.96	4.70	0.97	**4.63**	**0.98**	4.60	0.98	4.56	0.99	4.49	1.00
	10	4.35	0.92	4.30	0.93	**4.24**	**0.94**	4.21	0.94	4.18	0.94	4.11	0.96
	7	4.10	0.91	4.06	0.91	**4.00**	**0.92**	3.97	0.92	3.94	0.92	3.88	0.93
	5.5	3.50	0.85	3.46	0.85	**3.41**	**0.86**	3.38	0.86	3.36	0.86	3.31	0.87
	5	3.29	0.84	3.26	0.84	**3.21**	**0.85**	3.19	0.85	3.16	0.85	3.11	0.86
	2	2.99	0.81	2.95	0.81	**2.91**	**0.82**	2.89	0.82	2.87	0.82	2.82	0.83
	0	2.77	0.79	2.74	0.79	**2.70**	**0.80**	2.68	0.80	2.66	0.80	2.62	0.81
	-5	2.26	0.73	2.23	0.73	**2.20**	**0.74**	2.18	0.74	2.17	0.74	2.13	0.75
	-7	2.05	0.70	2.03	0.70	**2.00**	**0.71**	1.99	0.71	1.97	0.71	1.94	0.72
	-10	2.16	0.73	2.14	0.73	**2.11**	**0.74**	2.09	0.74	2.08	0.74	2.05	0.75
	-15	1.75	0.70	1.74	0.70	**1.71**	**0.71**	1.70	0.71	1.68	0.71	1.66	0.72
	-20	1.15	0.62	1.14	0.62	**1.12**	**0.63**	1.11	0.63	1.10	0.63	1.09	0.64
07+05	20	5.67	1.04	5.61	1.05	**5.53**	**1.06**	5.49	1.06	5.45	1.07	5.37	1.08
	15	5.23	1.00	5.18	1.01	**5.10**	**1.02**	5.06	1.02	5.02	1.03	4.95	1.04
	10	4.78	0.96	4.73	0.97	**4.66**	**0.98**	4.63	0.98	4.59	0.99	4.52	1.00
	7	4.56	0.94	4.51	0.95	**4.44**	**0.96**	4.41	0.96	4.37	0.96	4.31	0.98
	5.5	3.85	0.89	3.81	0.89	**3.75**	**0.90**	3.72	0.90	3.69	0.90	3.64	0.91
	5	3.62	0.88	3.58	0.88	**3.53**	**0.89**	3.50	0.89	3.48	0.89	3.43	0.90
	2	3.28	0.85	3.25	0.85	**3.20**	**0.86**	3.18	0.86	3.15	0.86	3.11	0.87
	0	3.05	0.82	3.01	0.82	**2.97**	**0.83**	2.95	0.83	2.93	0.83	2.88	0.84
	-5	2.48	0.76	2.46	0.76	**2.42**	**0.77**	2.40	0.77	2.38	0.77	2.35	0.78
	-7	2.26	0.74	2.23	0.74	**2.20**	**0.75**	2.18	0.75	2.17	0.75	2.13	0.76
	-10	2.38	0.76	2.35	0.76	**2.32**	**0.77**	2.30	0.77	2.29	0.77	2.25	0.78
	-15	1.93	0.73	1.91	0.73	**1.88**	**0.74**	1.87	0.74	1.85	0.74	1.82	0.75
	-20	1.26	0.64	1.25	0.64	**1.23**	**0.65**	1.22	0.65	1.21	0.65	1.19	0.66
10+05	20	5.67	1.04	5.61	1.05	**5.53**	**1.06**	5.49	1.06	5.45	1.07	5.37	1.08
	15	5.23	1.00	5.18	1.01	**5.10**	**1.02**	5.06	1.02	5.02	1.03	4.95	1.04
	10	4.78	0.96	4.73	0.97	**4.66**	**0.98**	4.63	0.98	4.59	0.99	4.52	1.00
	7	4.51	0.94	4.47	0.95	**4.40**	**0.96**	4.37	0.96	4.33	0.96	4.27	0.98
	5.5	3.85	0.89	3.81	0.89	**3.75**	**0.90**	3.72	0.90	3.69	0.90	3.64	0.91
	5	3.62	0.88	3.58	0.88	**3.53**	**0.89**	3.50	0.89	3.48	0.89	3.43	0.90
	2	3.28	0.85	3.25	0.85	**3.20**	**0.86**	3.18	0.86	3.15	0.86	3.11	0.87
	0	3.05	0.82	3.01	0.82	**2.97**	**0.83**	2.95	0.83	2.93	0.83	2.88	0.84
	-5	2.48	0.76	2.46	0.76	**2.42**	**0.77**	2.40	0.77	2.38	0.77	2.35	0.78
	-7	2.26	0.74	2.23	0.74	**2.20**	**0.75**	2.18	0.75	2.17	0.75	2.13	0.76
	-10	2.38	0.76	2.35	0.76	**2.32**	**0.77**	2.30	0.77	2.29	0.77	2.25	0.78
	-15	1.93	0.73	1.91	0.73	**1.88**	**0.74**	1.87	0.74	1.85	0.74	1.82	0.75
	-20	1.26	0.64	1.25	0.64	**1.23**	**0.65**	1.22	0.65	1.21	0.65	1.19	0.66
13+05	20	5.67	1.03	5.61	1.04	**5.53**	**1.05**	5.49	1.05	5.45	1.06	5.37	1.07
	15	5.23	0.99	5.18	1.00	**5.10**	**1.01**	5.06	1.01	5.02	1.02	4.95	1.03
	10	4.78	0.95	4.73	0.96	**4.66**	**0.97**	4.63	0.97	4.59	0.97	4.52	0.99
	7	4.51	0.93	4.47	0.94	**4.40**	**0.95**	4.37	0.95	4.33	0.95	4.27	0.97
	5.5	3.85	0.88	3.81	0.88	**3.75**	**0.89**	3.72	0.89	3.69	0.89	3.64	0.90
	5	3.62	0.87	3.58	0.87	**3.53**	**0.88**	3.50	0.88	3.48	0.88	3.43	0.89
	2	3.28	0.84	3.25	0.84	**3.20**	**0.85**	3.18	0.85	3.15	0.85	3.11	0.86
	0	3.05	0.81	3.01	0.81	**2.97**	**0.82**	2.95	0.82	2.93	0.82	2.88	0.83
	-5	2.48	0.75	2.46	0.75	**2.42**	**0.76**	2.40	0.76	2.38	0.76	2.35	0.77
	-7	2.26	0.73	2.23	0.73	**2.20**	**0.74**	2.18	0.74	2.17	0.74	2.13	0.75
	-10	2.38	0.76	2.35	0.76	**2.32**	**0.77**	2.30	0.77	2.29	0.77	2.25	0.78
	-15	1.93	0.72	1.91	0.72	**1.88**	**0.73**	1.87	0.73	1.85	0.73	1.82	0.74
	-20	1.26	0.64	1.25	0.64	**1.23**	**0.65**	1.22	0.65	1.21	0.65	1.19	0.66
07+07	20	5.67	1.04	5.61	1.05	**5.53**	**1.06**	5.49	1.06	5.45	1.07	5.37	1.08
	15	5.23	1.00	5.18	1.01	**5.10**	**1.02**	5.06	1.02	5.02	1.03	4.95	1.04
	10	4.78	0.96	4.73	0.97	**4.66**	**0.98**	4.63	0.98	4.59	0.99	4.52	1.00
	7	4.51	0.94	4.47	0.95	**4.40**	**0.96**	4.37	0.96	4.33	0.96	4.27	0.98
	5.5	3.85	0.89	3.81	0.89	**3.75**	**0.90**	3.72	0.90	3.69	0.90	3.64	0.91
	5	3.62	0.88	3.58	0.88	**3.53**	**0.89**	3.50	0.89	3.48	0.89	3.43	0.90
	2	3.28	0.85	3.25	0.85	**3.20**	**0.86**	3.18	0.86	3.15	0.86	3.11	0.87
	0	3.05	0.82	3.01	0.82	**2.97**	**0.83**	2.95	0.83	2.93	0.83	2.88	0.84
	-5	2.48	0.76	2.46	0.76	**2.42**	**0.77**	2.40	0.77	2.38	0.77	2.35	0.78
	-7	2.26	0.74	2.23	0.74	**2.20**	**0.75**	2.18	0.75	2.17	0.75	2.13	0.76
	-10	2.38	0.76	2.35	0.76	**2.32**	**0.77**	2.30	0.77	2.29	0.77	2.25	0.78
	-15	1.93	0.73	1.91	0.73	**1.88**	**0.74**	1.87	0.74	1.85	0.74	1.82	0.75
	-20	1.26	0.64	1.25	0.64	**1.23**	**0.65**	1.22	0.65	1.21	0.65	1.19	0.66

TC : Total capacity [kW]
PI ; Power input [kW]

Heating

2 - room multisplit : 2 - unit operation

Indoor units : **10 type + 07 type**
13 type + 07 type
10 type + 10 type
13 type + 10 type
13 type + 13 type

Outdoor unit : RAS-2M14U2AVG-E

Combination Capacity	Outdoor air temp [°C WB]	Indoor air temp [°C DB]											
		16.0 °C DB		18.0 °C DB		20.0 °C DB		21.0 °C DB.		22.0 °C DB		24.0 °C DB	
		TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]	TC [kW]	PI [kW]
10+07	20	5.67	1.03	5.61	1.04	5.53	1.05	5.49	1.05	5.45	1.06	5.37	1.07
	15	5.23	0.99	5.18	1.00	5.10	1.01	5.06	1.01	5.02	1.02	4.95	1.03
	10	4.78	0.95	4.73	0.96	4.66	0.97	4.63	0.97	4.59	0.97	4.52	0.99
	7	4.51	0.93	4.47	0.94	4.40	0.95	4.37	0.95	4.33	0.95	4.27	0.97
	5.5	3.85	0.88	3.81	0.88	3.75	0.89	3.72	0.89	3.69	0.89	3.64	0.90
	5	3.62	0.87	3.58	0.87	3.53	0.88	3.50	0.88	3.48	0.88	3.43	0.89
	2	3.28	0.84	3.25	0.84	3.20	0.85	3.18	0.85	3.15	0.85	3.11	0.86
	0	3.05	0.81	3.01	0.81	2.97	0.82	2.95	0.82	2.93	0.82	2.88	0.83
	-5	2.48	0.75	2.46	0.75	2.42	0.76	2.40	0.76	2.38	0.76	2.35	0.77
	-7	2.26	0.73	2.23	0.73	2.20	0.74	2.18	0.74	2.17	0.74	2.13	0.75
	-10	2.38	0.76	2.35	0.76	2.32	0.77	2.30	0.77	2.29	0.77	2.25	0.78
	-15	1.93	0.72	1.91	0.72	1.88	0.73	1.87	0.73	1.85	0.73	1.82	0.74
	-20	1.26	0.64	1.25	0.64	1.23	0.65	1.22	0.65	1.21	0.65	1.19	0.66
13+07	20	5.67	0.99	5.61	1.00	5.53	1.01	5.49	1.01	5.45	1.02	5.37	1.03
	15	5.23	0.96	5.18	0.97	5.10	0.98	5.06	0.98	5.02	0.99	4.95	1.00
	10	4.78	0.92	4.73	0.93	4.66	0.94	4.63	0.94	4.59	0.94	4.52	0.96
	7	4.51	0.91	4.47	0.91	4.40	0.92	4.37	0.92	4.33	0.92	4.27	0.93
	5.5	3.85	0.85	3.81	0.85	3.75	0.86	3.72	0.86	3.69	0.86	3.64	0.87
	5	3.62	0.84	3.58	0.84	3.53	0.85	3.50	0.85	3.48	0.85	3.43	0.86
	2	3.28	0.81	3.25	0.81	3.20	0.82	3.18	0.82	3.15	0.82	3.11	0.83
	0	3.05	0.79	3.01	0.79	2.97	0.80	2.95	0.80	2.93	0.80	2.88	0.81
	-5	2.48	0.73	2.46	0.73	2.42	0.74	2.40	0.74	2.38	0.74	2.35	0.75
	-7	2.26	0.70	2.23	0.70	2.20	0.71	2.18	0.71	2.17	0.71	2.13	0.72
	-10	2.38	0.73	2.35	0.73	2.32	0.74	2.30	0.74	2.29	0.74	2.25	0.75
	-15	1.93	0.70	1.91	0.70	1.88	0.71	1.87	0.71	1.85	0.71	1.82	0.72
	-20	1.26	0.62	1.25	0.62	1.23	0.63	1.22	0.63	1.21	0.63	1.19	0.64
10+10	20	5.67	1.00	5.61	1.01	5.53	1.02	5.49	1.02	5.45	1.03	5.37	1.04
	15	5.23	0.97	5.18	0.98	5.10	0.99	5.06	0.99	5.02	1.00	4.95	1.01
	10	4.78	0.93	4.73	0.94	4.66	0.95	4.63	0.95	4.59	0.95	4.52	0.97
	7	4.51	0.92	4.47	0.92	4.40	0.93	4.37	0.93	4.33	0.93	4.27	0.95
	5.5	3.85	0.86	3.81	0.86	3.75	0.87	3.72	0.87	3.69	0.87	3.64	0.88
	5	3.62	0.85	3.58	0.85	3.53	0.86	3.50	0.86	3.48	0.86	3.43	0.87
	2	3.28	0.82	3.25	0.82	3.20	0.83	3.18	0.83	3.15	0.83	3.11	0.84
	0	3.05	0.79	3.01	0.79	2.97	0.80	2.95	0.80	2.93	0.80	2.88	0.81
	-5	2.48	0.74	2.46	0.74	2.42	0.75	2.40	0.75	2.38	0.75	2.35	0.76
	-7	2.26	0.71	2.23	0.71	2.20	0.72	2.18	0.72	2.17	0.72	2.13	0.73
	-10	2.38	0.74	2.35	0.74	2.32	0.75	2.30	0.75	2.29	0.75	2.25	0.76
	-15	1.93	0.70	1.91	0.70	1.88	0.71	1.87	0.71	1.85	0.71	1.82	0.72
	-20	1.26	0.62	1.25	0.62	1.23	0.63	1.22	0.63	1.21	0.63	1.19	0.64
13+10	20	5.67	0.98	5.61	0.99	5.53	1.00	5.49	1.00	5.45	1.01	5.37	1.02
	15	5.23	0.95	5.18	0.96	5.10	0.97	5.06	0.97	5.02	0.97	4.95	0.99
	10	4.78	0.92	4.73	0.92	4.66	0.93	4.63	0.93	4.59	0.93	4.52	0.95
	7	4.51	0.90	4.47	0.90	4.40	0.91	4.37	0.91	4.33	0.91	4.27	0.92
	5.5	3.85	0.84	3.81	0.84	3.75	0.85	3.72	0.85	3.69	0.85	3.64	0.86
	5	3.62	0.83	3.58	0.83	3.53	0.84	3.50	0.84	3.48	0.84	3.43	0.85
	2	3.28	0.80	3.25	0.80	3.20	0.81	3.18	0.81	3.15	0.81	3.11	0.82
	0	3.05	0.78	3.01	0.78	2.97	0.79	2.95	0.79	2.93	0.79	2.88	0.80
	-5	2.48	0.72	2.46	0.72	2.42	0.73	2.40	0.73	2.38	0.73	2.35	0.74
	-7	2.26	0.69	2.23	0.69	2.20	0.70	2.18	0.70	2.17	0.70	2.13	0.71
	-10	2.38	0.72	2.35	0.72	2.32	0.73	2.30	0.73	2.29	0.73	2.25	0.74
	-15	1.93	0.69	1.91	0.69	1.88	0.70	1.87	0.70	1.85	0.70	1.82	0.71
	-20	1.26	0.61	1.25	0.61	1.23	0.62	1.22	0.62	1.21	0.62	1.19	0.63
13+13	20	5.67	0.96	5.61	0.97	5.53	0.98	5.49	0.98	5.45	0.99	5.37	1.00
	15	5.23	0.93	5.18	0.94	5.10	0.95	5.06	0.95	5.02	0.95	4.95	0.97
	10	4.78	0.90	4.73	0.90	4.66	0.91	4.63	0.91	4.59	0.91	4.52	0.92
	7	4.51	0.88	4.47	0.88	4.40	0.89	4.37	0.89	4.33	0.89	4.27	0.90
	5.5	3.85	0.82	3.81	0.82	3.75	0.83	3.72	0.83	3.69	0.83	3.64	0.84
	5	3.62	0.81	3.58	0.81	3.53	0.82	3.50	0.82	3.48	0.82	3.43	0.83
	2	3.28	0.78	3.25	0.78	3.20	0.79	3.18	0.79	3.15	0.79	3.11	0.80
	0	3.05	0.76	3.01	0.76	2.97	0.77	2.95	0.77	2.93	0.77	2.88	0.78
	-5	2.48	0.70	2.46	0.70	2.42	0.71	2.40	0.71	2.38	0.71	2.35	0.72
	-7	2.26	0.68	2.23	0.68	2.20	0.69	2.18	0.69	2.17	0.69	2.13	0.70
	-10	2.38	0.71	2.35	0.71	2.32	0.72	2.30	0.72	2.29	0.72	2.25	0.73
	-15	1.93	0.67	1.91	0.67	1.88	0.68	1.87	0.68	1.85	0.68	1.82	0.69
	-20	1.26	0.59	1.25	0.59	1.23	0.60	1.22	0.60	1.21	0.60	1.19	0.61

TC : Total capacity [kW]
PI ; Power input [kW]

TOSHIBA CARRIER (THAILAND) CO.,LTD.
144/9 Moo 5, Bangkadi Industrial Park, Tivanon Road, Tambol Bangkadi,
Amphur Muang, Pathumthani 12000, Thailand